



A division of Industrial Piping Solutions (Pty) Ltd.

Cell: 082-500-0731 Office

Cell: 082-781-4329 Sales


Fax: 086-540-0825

info@ScaleAway.co.za

www.ScaleAway.co.za

ScaleAway Descaling Large Boilers - Product Data Sheet

Descaling Larger Boilers



PRODUCT DESCRIPTION

Choice of Descaling Chemical and Quantity Required:
ScaleAway C120 model Descaling Pump.

ScaleAwayBIO may be used with virtually all commercial and industrial boilers. Should there be any aluminium surfaces in the boiler, then *ScaleAwayLime-Go* should be used.

Should there be any stainless steel in the construction of the boiler, then use *ScaleAwayBIO*.

INSTRUCTIONS

1. Calculate the amount of descaling chemical required. As a guide, for a 1,000 litre capacity boiler, use 4 x 25 litres descaling chemical (i.e. a 10% solution by volume). A weaker solution may be used, but will take longer to remove scale.
2. In the above example, a descaling pump of 100+ litres tank capacity will allow all the descaling chemical to be placed directly in the pump tank, without any need to first drain out a corresponding volume of water from the boiler.
3. A descaling pump with a smaller tank would first require some water to be drained from the boiler. The tank of the pump would then need to be filled with descaling chemical several times, each time operating the pump briefly to transfer the chemical into the boiler, before commencing normal circulation.

4. The chemical will rapidly dilute to the working strength on commencing circulation.
5. A chart to calculate the approximate volume of a cylindrical boiler from its length and diameter is available from ScaleAway. However, allowance should be made for the volume of the combustion chamber and fire-tubes, and it is preferable to ascertain water capacity from manufacturers' specifications.

HANDLING

Note 1:

When descaling with any acid, some hydrogen gas may be evolved. Hydrogen is a flammable gas, and the working area should be well ventilated. Avoid smoking nearby, or any other means of ignition.

Note 2:

APPLICATION OF HEAT.

Heat may be applied to the boiler, but ONLY BEFORE ADDITION OF THE DESCALING CHEMICAL, and whilst full circulation is still possible (i.e. before isolation from heating system). Increasing the temperature to a maximum temperature of 50°C will speed up descaling. After firing the boiler, allow circulation for half an hour before isolation, and check temperature again before introduction of descaling chemical.

The *ScaleAway C120* model pump incorporate engineering plastics components to give high resistance to chemical attack. Consequently the descaling solution must not be allowed to rise above 80°C whilst the pump is in use.



A division of Industrial Piping Solutions (Pty) Ltd.

Cell: 082-500-0731 Office

Cell: 082-781-4329 Sales

Fax: 086-540-0825

info@ScaleAway.co.za

www.ScaleAway.co.za

ScaleAway Descaling Large Boilers - Product Data Sheet

Descaling Larger Boilers

PROCEDURE

1. Ensure an adequate water supply to dilute or neutralise any chemical leaks, or the spent descaling chemical, so that disposal does not contravene local regulations.
2. Disconnect or isolate water inlets / feed-pump and hot water return pipework.
3. Disconnect or isolate hot water or steam outlet.
4. Disconnect or isolate any connections to pressure gauges, boiler water sampling lines etc.
5. Isolate water level gauges and other level devices, and open their drain lines.
6. Connect a hose from descaling pump to blow-down valve fitting or drain valve. In the case of drain valves, check that valve is clear and will pass water through at a reasonable rate. If necessary clear a passage through any blockage.
7. The pump connection to the lower point of the boiler should always be through a valve. Failing this, power failure to the pump would result in the head of water in the boiler causing the liquid level in the descaling pump tank to rise and overflow, unless prevented by closing the valve. The *ScaleAway C120* model has integral valves suitable for this purpose.
8. Connect the other (return) pump hose to a suitable high point / pipe fitting on the boiler, as far from the inlet hose as practicable.
9. Connections should be made so that there is a complete circuit between the output hose, through the boiler to the return hose.
10. Venting of the carbon dioxide gas evolved is achieved through the pump tank filler cap aperture. The cap should be screwed on by no more than one quarter of a turn. This is sufficient to vent the gas, but at the same time reduces fumes and prevents splashes.
11. Connect the pump to a suitable earthed power supply (220 volt, according to model). As the pump will be used in a damp location, we recommend that a residual current circuit breaker plug-top be used.
12. The direction in which the flow reverser handle points indicates the direction of flow of the liquid. Operate the handle so that it points initially towards the hose connected to the base / drain valve of the boiler. The hose from the top of the boiler will then be the return to the pump tank.
13. Prior to adding descaling chemical to pump tank, first 'prove' the circuit with fresh water alone. Add water to pump tank to approx. 4" (10cm) above minimum liquid level, switch on pump, and immediately open the boiler drain valve (the lower hose connection point) to allow circulation to commence. If water level drops initially, add more water to tank, and check that all connections are tight.
14. To commence descaling, slowly add descaling chemical to pump tank. As liquid returns from the boiler check for a rapid build-up of foam on top of the liquid in the descaling pump tank. This may happen when there is a large amount of reactive limescale in the base of the boiler. If this is excessive, add *ScaleAway Bubble-Buster* to the tank to reduce the foaming.
15. As circulation commences, bubbles in the return hose to the pump from the top of the boiler, indicate that limescale is being dissolved.
16. Continue circulation through the boiler and descaling pump, briefly reversing the direction of flow periodically.
17. Check all connections regularly for tightness and leaks. If foaming is excessive, add more *ScaleAway Bubble-Buster* to the pump tank.
18. Scale removal can be considered complete when bubbles are no longer seen in the return pipe, and yet the descaling solution is still sufficiently strong to remove hard water deposits.
19. *ScaleAway BIO* descaling chemical contains a built-in colour change to monitor strength, and so the strength of the *ScaleAway BIO* solution may be monitored visually.
20. A simple check may be made by dropping a sample of limescale into the solution, and observing if there is any effervescence.
21. Alternatively, a pH meter, or pH indicator paper, may also be used to check the pH of the descaling solution. Once the pH has risen to 3.5 to 4, its ability to dissolve limescale and corrosion deposits is effectively spent, and more descaling chemical or a fresh solution will be required.



A division of Industrial Piping Solutions (Pty) Ltd.

Cell: 082-500-0731 Office

Cell: 082-781-4329 Sales

Fax: 086-540-0825

info@ScaleAway.co.za

www.ScaleAway.co.za

ScaleAway Descaling Large Boilers - Product Data Sheet

Descaling Larger Boilers

22. After draining the spent descaling chemical, flush the boiler with fresh water. Many natural waters are slightly alkaline, and water flushing may be all that is required.
23. Alternatively, circulate a 0.5 to 1% solution of ScaleAway pH-Buffer through the boiler for 15 minutes, drain, and then flush with more clean water.
24. Operators may prefer to neutralise the spent descaling solution "in situ" whilst the liquid is still circulating, by adding neutralising crystals to the solution until the pH is increased to 7 (neutral), and then flushing to drain.

If you have a ScaleAwayScalebreaker FWF type descaling pump, this has an integral fresh water flushing facility:

SAFETY AND HANDLING

When descaling is complete, the spent descaling solution may be pumped to waste along the dump hose as follows:

If the flow reverser lever is to the left, twist the right-hand dump valve through 180°C to show the word 'dump', ensuring that the left-hand valve remains in the 'circulation' position.

(If the flow reverser lever is to the right, twist the left-hand dump valve through 180°C to show the word 'dump', ensuring that the right-hand valve remains in the 'circulation' position).

When 'dumping', the water level in the pump tank will fall by the same volume as is being dumped. Open the mains water supply valve and adjust to allow fresh water to enter the tank at the same rate as water is exiting the dump hose. Make sure that the tank water level remains at least 10 cm (4") above the minimum mark.

Continue dumping until fresh water is leaving the end of the dump hose.

Turn the valve which is in 'dump' mode through 180°C to restore full circulation through the pump and the system.

Close the water supply inlet valve once the level in the reservoir has stabilised between minimum and maximum markers.

Allow fresh water to circulate through the descaled equipment for ten minutes.

PRECAUTIONS

IMPORTANT: When working with acidic descaling chemicals, always wear suitable protective clothing and goggles. Refer to instructions on labels of descaling chemicals, and refer to Material Safety Data Sheets.

Caps should be kept securely on all chemical containers whilst not in use. To avoid splashes, operators should not stand directly over open chemical containers or the filling neck of the descaling pump whilst pouring or adding chemicals.

Legal disclaimer: It is stressed that these are guidance notes only, and the above information is based on the present state of our knowledge of boilers in general. It is given in good faith, but due to the diverse and varied nature of such equipment, and its application, the user must satisfy himself that the above procedure is viable in the prevailing situation.